

City of Woodland

COMMUNITY DEVELOPMENT DEPARTMENT  
300 FIRST STREET WOODLAND, CA 95695  
(530) 661-5820 (530) 406-0832 FAX  
<http://www.cityofwoodland.org>

## **Safety Barriers for Residential Swimming Pool Hot Tub & Spa**

**2013 California Residential Code (CRC) Appendix G - Requirements**

**Purpose:** These barrier requirements apply to New and Remodeled Swimming Pools, Hot Tubs & Spas, and to Alterations to the code-regulated Security Barriers and Safety Features

**Definition—Swimming Pool:** Any structure intended for swimming or recreational bathing that contains water over 24 inches deep. This includes in-ground, above-ground and on-ground swimming pools, hot tubs and spas.


### **Outdoor Swimming Pool—Safety Barriers**

The following general compliance requirements for an outdoor swimming pool including an in-ground, above ground or on-ground pool, hot tub, or spa shall be provided with a barrier which shall comply with the following:

1. The top of the barrier shall be at least **60-inches\*** above grade measured on the side of the barrier, which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier shall be 2 inches measured on the side of the barrier, which faces away from the swimming pool. Where the top of the pool structure is above grade, such as an aboveground pool, the barrier may be at ground level, such as the pool structure, or mounted on top of the pool structure. Where the barrier is mounted on top of the pool structure, the maximum vertical clearance between the top of the pool structure and the bottom of the barrier shall be 4 inches.
2. Openings in the barrier shall not allow passage of a 4-inch-diameter sphere.
3. Solid barriers that do not have openings, such as a masonry or stone wall, shall not contain indentations or protrusions except for normal construction tolerances and tooled masonry joints.
4. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 45 inches, the horizontal members shall be located on the swimming pool side of the fence. Spacing between vertical members shall not exceed 1.75 inches in width. Where there are decorative cut outs within vertical members, spacing within the cutouts shall not exceed 1.75 inches in width.
5. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 45 inches or more, spacing between vertical members shall not exceed 4 inches. Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1.75 inches in width.
6. Where the barrier is composed of diagonal members, such as a lattice fence, the maximum opening formed by the diagonal members shall not be more than 1.75 inches.

\* As amended by City of Woodland Municipal Code 6-1-9(J)1

Continue on other side



City of Woodland

COMMUNITY DEVELOPMENT DEPARTMENT  
300 FIRST STREET WOODLAND, CA 95695  
(530) 661-5820 (530) 406-0832 FAX  
<http://www.cityofwoodland.org>

## **Safety Barriers for Residential Swimming Pool, Hot Tub, & Spa**

2013 California Residential Code (CRC) Appendix G - Requirements

### **Outdoor Swimming Pool Safety Barriers – continue**

7. The Maximum mesh size for chain link fences shall be a 2.25-inch square unless the fence is provided with slats fastened at the top or the bottom which reduce the openings to not more than 1.75 inches. **(residential chain link fences may not be permitted by Woodland Planning Division—contact Planning for type of fencing materials allowed in your area).**
8. Access gates shall be equipped to accommodate a locking device. Pedestrian access gates shall open outward away from the pool and shall be self-closing and have a self-latching device. Gates other than pedestrian access gates shall have a self-latching device. Where the release mechanism of the self-latching device is located less than 54 inches from the bottom of the gate, the release mechanism and openings shall comply with the following:
  - 8.1. The release mechanism shall be located on the pool side of the gate at least 3 inches below the top of the gate, **and**
  - 8.2. The gate and barrier shall have no opening greater than 0.5 inch within 18 inches of the release mechanism.
9. Where a wall of a dwelling serves as part of the barrier, one of the following conditions shall be met:
  - 9.1. The pool shall be equipped with a powered safety cover in compliance with *ASTM F 1346*; **or**
  - 9.2. Doors with direct access to the pool through that wall shall be equipped with an alarm which produces an audible warning when the door and/or its screen, if present, are opened. The alarm shall be listed and labeled in accordance with UL2017. The deactivation switch(es) shall be located at least 54 inches above the threshold of the door; **or**
  - 9.3. Other means of protection, such as self-closing doors with self-latching devices, which are approved by the governing body, shall be acceptable as long as the degree of protection afforded is not less than the protection afforded by *Item 9.1 or 9.2* described above.
10. Where an aboveground pool structure is used as a barrier or where the barrier is mounted on top of the pool structure, and the means of access is a ladder or steps, then:
  - 10.1. The ladder or steps shall be capable of being secured, locked or removed to prevent access, **or**
  - 10.2. The ladder or steps shall be surrounded by a barrier, which meets the requirements of *Section AG105.2, Items 1 through 9*. When the ladder or steps are secured, locked or removed, any opening created shall not allow the passage of a 4-inch-diameter sphere.

**Indoor swimming pool.** Walls surrounding an indoor swimming pool shall comply with, *Item 9 above*.

**Prohibited locations.** Barriers shall be located to prohibit permanent structures, equipment or similar objects from being used to climb them.

**Barrier exceptions.** Spas or hot tubs with a safety cover which complies with *ASTM F 1346*, as listed in *Section AG105.2, AG105.5*, shall be exempt from the above provisions.